

NOTE: DIMENSIONS IN [ ] ARE ENGLISH STANDARD EQUIVALENTS.

REV	DATE	CHANGE NUMBER	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
-	22JAN2021	CT209473	NEW DRAWING	RVM

UNLESS OTHERWISE SPECIFIED:  
ALL DIMENSIONS IN MILLIMETERS  
GENERAL TOLERANCES:  
XX ± 0.25  
XX ± 1.0  
X ± 1.5  
ANGLES ± 0°30'

SURFACE FINISH  
MAX.

THIRD ANGLE PROJECTION

MAJOR ○ = 0  
CRITICAL ⊙ = 0  
CHARACTERISTICS COMPLY WITH  
KPS-50022

DRAWN BY RVM DATE:  
APPROVED BY TAS 22JAN2021

DO NOT SCALE.  
THIS ASSEMBLY OR PART MUST COMPLY WITH PEP-RML-001.  
REFERENCE CAD MODEL FOR UNSPECIFIED DIMENSIONS.





**KOHLER.**  
KOHLER, WISCONSIN 53044

SCALE: 0.060 SHEET SIZE: B SHEET 1 OF 2

TITLE:  
**DIMENSION PRINT, 24RCLA**

DWG NO.: **ADV-9758**

24RCLA



**INSTALLATION GUIDELINES**

- 1) EXHAUST IS AIMED AWAY FROM OR PARALLEL TO THE STRUCTURE.
- 2) EXHAUST IS NOT DIRECTED AT PLAY AREAS, PATIOS OR OTHER AREAS WHERE PEOPLE CONGREGATE.
- 3) THE NEAREST WINDOW, VENT, DOOR OR SIMILAR STRUCTURE OPENING IS AT LEAST 5 FEET FROM THE EXHAUST END OF THE GENERATOR.
- 4) GENERATOR SET MUST BE INSTALLED A MINIMUM OF 18 INCHES FROM STRUCTURE PER NFPA 37, HOWEVER, ACTUAL DISTANCE MAY DIFFER BASED ON STATE AND LOCAL CODES.
- 5) WINDOWS & DOORS ON ADJACENT WALLS ARE CLOSED.
- 6) FURNACE AND OTHER SIMILAR INTAKES ARE AT LEAST 10 FEET FROM EXHAUST END OF GENERATOR.
- 7) 4" THICK CONCRETE PAD EXTENDING 6" BEYOND GENSET ON ALL SIDES.
- 8) NO PLANTS, SHRUBS OR OTHER COMBUSTIBLES ALLOWED IN CLEARANCE AREA. (MINIMUM 8 FT. FROM EXHAUST END).
- 9) SENSITIVE PLANTS, PATIO FURNITURE, ETC. ARE AT LEAST 8 FEET FROM EXHAUST END OF SET.
- 10) REFER TO OWNERS MANUAL FOR OTHER INSTALLATION CONSTRAINTS.

24RCLA

REV	DATE	CHANGE NUMBER	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL □ INDICATES PART NUMBERS AFFECTED BY LATEST DRAWING REVISION	BY
-	22JAN2021	CT209473	NEW DRAWING	RVM

UNLESS OTHERWISE SPECIFIED:  
ALL DIMENSIONS IN MILLIMETERS  
GENERAL TOLERANCES:  
XX ± 0.25  
X.X ± 1.0  
X ± 1.5  
ANGLES ± 0°30'

THIRD ANGLE PROJECTION

MAJOR ○ = 0  
CRITICAL ⊙ = 0  
CHARACTERISTICS COMPLY WITH KPS-50022

DRAWN BY RVM DATE: 22JAN2021  
APPROVED BY TAS

DO NOT SCALE. THIS ASSEMBLY OR PART MUST COMPLY WITH PEP-RML-001. REFERENCE CAD MODEL FOR UNSPECIFIED DIMENSIONS.

**KOHLER.**  
KOHLER, WISCONSIN 53044

SCALE: 0.150 SHEET SIZE: B SHEET 2 OF 2

TITLE:  
**DIMENSION PRINT, 24RCLA**

DWG NO.: **ADV-9758**